

CHLORINE INSTITUTE EMERGENCY KIT

VITON GASKET SETS

The Chlorine Institute Gasket Guidelines also recommend a maximum 4 year shelf life for all gaskets made of Viton. All emergency kit gaskets are stamped with the date of manufacture for ease of inspection.

AVGS



BVGS



CVGS



AXGS 1993-2013



BXGS BEFORE 2014



For Kit-A

Design	Hood	Status	Gasket	Status	Replacement Gasket Set or Conversion Pkg.
Pre-1986	1A	Unavailable	1B	Unavailable	AC13A Conversion Pkg.
1986-1993	1A1	Unavailable	1BMV	Unavailable	AC13A Conversion Pkg.
1993-2013	1A2	Unavailable	1BRV	Available	AXGS Gasket Set
2013 -Current	1A3	Available	1BRV	Available	AVGS Gasket Set

VITON GASKET SETS

AVGS Chlorine Institute Emergency Kit A Gasket Set - (Current as of Jan. 1, 2013)
Includes: (2) 1BRV gaskets, (2) 8GV gaskets

BVGS Chlorine Institute Emergency Kit B Gasket Set (Current as of May 1, 2014)
Includes: (2) 4-12BMV gaskets, (1) 12BBV gaskets, (1) 12MV gaskets, (2) 9GV gaskets

CVGS Chlorine Institute Emergency Kit C Gasket Set Includes: (2) 6BMV gaskets, (2) 24BMV gaskets

AXGS Chlorine Institute Emergency Kit A Gasket Set (Kits Manufactured between 1993 - 2012)
Includes: (2) 1BRV gaskets, (2) 8EV gaskets

BXGS Chlorine Institute Emergency Kit "B" Gasket Set (Kits Manufactured prior to May 2014)
Includes: (2) 4-12BMV gaskets, (1) 12BBV gaskets, (1) 12MV gaskets, (2) 9EV gaskets

The Chlorine Institute Emergency Kits include gaskets made of Viton (since 1978) which are recommended by the Chlorine Institute to be inspected on a regular basis. Gaskets found to be impaired or used in an emergency situation should be replaced.

INDIANSPRINGS

P.O. BOX 469 BALDWINVILLE, N.Y. 13027-0469 (315) 635-6101 Fax (315) 635-7473
www.indiansprings.com