

Truflo #TF550

Fits Inside a 5¼" Valve Box!



- Fits inside a standard 5¼" valve box
- Alternative to two valve box blow-off
- Easy to maintain without digging
- Provides powerful "full channel flow"
- 2" MIP Outlet
- 2" FIP Vertical (Straight) Inlet


TRUFLO™

SIMPLE




Compact unit is easy to handle and install.

NO DIGGING



Maintenance is done without digging by removing four bolts from above.

EASY




Fits easily inside any valve box of your choosing.



Kupferle
2511 North 9th Street
St. Louis, MO 63102
800-231-3990 / www.hydrants.com
Contact us at info@hydrants.com



TF550 BLOW OFF



Hydrant shall have a 2" vertical FP inlet and a 2" NPT nozzle outlet. Hydrant shall be operated by turning a top-mounted $\frac{9}{16}$ " square nut counterclockwise to open, clockwise to close. All internal working parts, the inlet, and the outlet shall be brass. All working parts shall be serviceable from above with no digging required. All wear parts (o-rings and valve seat) shall be commonly available dimensions and materials, and none may be vendor-unique design. Hydrant shall be model TF550 as manufactured by Kupperle Foundry Co., St. Louis, Mo. 63102.

-insure that the hydrant is free to move vertically within the valve box in order to prevent the transmission of traffic loads to the hydrant. It should not be jammed or wedged against the valve box ID.

-The normal position of the top of the operating nut is about 6" below the top of the valve box. But you can freely adjust this position to suit your circumstances. Just keep in mind the maintenance procedures are best performed when bolts attaching the top cap are within an easy reach.

-Follow the suggestions of the AWWA for hydrant installation.

DATE	REVISION

THIS DRAWING IS THE PROPERTY OF THE KUPPERLE FOUNDRY COMPANY. IT IS NOT TO BE USED OR DUPLICATED WITHOUT PERMISSION OF THE OWNER.

DRAWN	F.M.
APPROVED	
DATE	11-14-12
MAT'L	

PART NO. #TF550 BLOW OFF SHEET 1 OF 1

ECLIPSE
Since 1887

KUPPERLE FOUNDRY COMPANY

2611 NORTH 9TH STREET, ST. LOUIS, MO 63102
314-231-8738 800-231-3990 FAX 314-231-2820
<http://www.hydranta.com>