

EXTENSION KIT FOR  AVK MODELS 2700 & 2800 FIRE HYDRANTS

SPECIFICATIONS


ITEM NUMBER	DESCRIPTION	MATERIAL	QTY.
1	Standpipe Gasket	Molded "T" Neoprene	2
2	Hydrant Lubricant	FDA Approved Mineral Oil	1
3	Standpipe Extension	Ductile Pipe	1
4	Extension Stem	Steel	1
5	Bolt & Nut	Zinc-Plated Steel	4
6	Standpipe Flange	Ductile Iron	2
7	Extension Stem Coupling	Steel	1
8	Snap Ring	Stainless Steel	2
9	Clevis Pin	Stainless Steel	2
10	Cotter Pin	Stainless Steel	2

SIZE: 5¼" Main Valve Opening

HRPI Products are engineered and manufactured using the latest computerized technology to ensure quality products with repeatable tolerances.

HRPI Guarantees this product to be compatible, and will operate with the fire hydrant when installed properly. The use of this product shall not affect any published warranties available to the buyer.

PRODUCTS MEET OR EXCEED THE AWWA C502 STANDARD FOR DRY-BARREL FIRE HYDRANTS.



FAX: (918) 224-6857

 **Hydrant Repair Parts, Inc.**
 7900 New Sapulpa Road, Tulsa, OK 74131 • (918) 224-8713
 1-800-776-8713 or 1-800-548-9123