

EXTENSION KITS FOR  CLOW 2500 FIRE HYDRANTS

SPECIFICATIONS


ITEM NUMBER	DESCRIPTION	MATERIAL	QTY.
1	Upper Standpipe Gasket	Neoprene	1
2	Standpipe Extension	Ductile Pipe	1
3	Extension Stem	Steel	1
4	Bolt & Nut	Zinc-Plated Steel	8
5	Unbreakable Standpipe Flange	Ductile Iron	2
6	Extension Stem Coupling	Cast Iron	1
7	Snap Ring	Stainless Steel	2
8	Coupling Bolt & Nut	Stainless Steel	2
9	Lower Standpipe Gasket	Molded "T" Neoprene	1

SIZE: 4½" or 5¼" Main Valve Opening

HRPI Products are engineered and manufactured using the latest computerized technology to ensure quality products with repeatable tolerances.

HRPI Guarantees this product to be compatible, and will operate with the fire hydrant when installed properly. The use of this product shall not affect any published warranties available to the buyer.

PRODUCTS MEET OR EXCEED THE AWWA C502 STANDARD FOR DRY-BARREL FIRE HYDRANTS.



FAX: (918) 224-6857

Hydrant Repair Parts, Inc.

7900 New Sapulpa Road, Tulsa, OK 74131 • (918) 224-8713

1-800-776-8713 or 1-800-548-9123