

## SPECIFICATIONS


ITEM NUMBER	DESCRIPTION	MATERIAL	QTY.
1	Bolt & Nut	Zinc-Plated Steel	8
2	Breakable Flange (HALF-CIRCLE)	Cast Iron	2
3	Breakable Stem Coupling	Cast Iron	1
4	Clevis Pin	Stainless Steel	2
5	Cotter Pin	Stainless Steel	2
6	Standpipe "O"-Ring	Lathe-Cut Buna-N Rubber	1
7	Bonnet Gasket (NOT SHOWN)	Cloth-Inserted SBR Rubber	1

SIZE: 4½" or 5¼" Main Valve Opening

HRPI Products are engineered and manufactured using the latest computerized technology to ensure quality products with repeatable tolerances.

HRPI Guarantees this product to be compatible, and will operate with the fire hydrant when installed properly. The use of this product shall not affect any published warranties available to the buyer.

PRODUCTS MEET OR EXCEED THE AWWA C502 STANDARD FOR DRY-BARREL FIRE HYDRANTS.



FAX: (918) 224-6857

# Hydrant Repair Parts, Inc.

7900 New Sapulpa Road, Tulsa, OK 74131 • (918) 224-8713

1-800-776-8713 or 1-800-548-9123

Guardian is a registered trademark of Kennedy Valve Co., a division of McWane, Inc., Elmira, NY.  
Hydrant Repair Parts, Inc., is not affiliated with Kennedy Valve Co.