

SPECIFICATIONS


ITEM NUMBER	DESCRIPTION	MATERIAL	QTY.
1	Upper Flange "O"-Ring	Buna-N Rubber	1
2	Extension Barrel	Ductile Iron	1
3	Extension Stem	Steel	1
4	Hydrant Lubricant	FDA Approved Mineral Oil	1
5	Bolt & Nut	Zinc-Plated Steel	8
6	Extension Stem Coupling	Stainless Steel	1
7	Cotter Pin	Stainless Steel	2
8	Clevis Pin	Stainless Steel	2
9	Flange Gasket	Cloth-Inserted SBR Rubber	2
10	Extension Flange (SET)	Ductile Iron	1
11	Bonnet "O"-Ring (Not Shown)	Buna-N Rubber	1

SIZE: 4½" or 5¼" Main Valve Opening

HRPI Products are engineered and manufactured using the latest computerized technology to ensure quality products with repeatable tolerances.

HRPI Guarantees this product to be compatible, and will operate with the fire hydrant when installed properly. The use of this product shall not affect any published warranties available to the buyer.

PRODUCTS MEET OR EXCEED THE AWWA C502 STANDARD FOR DRY-BARREL FIRE HYDRANTS.



FAX: (918) 224-6857

Hydrant Repair Parts, Inc.

7900 New Sapulpa Road, Tulsa, OK 74131 • (918) 224-8713

1-800-776-8713 or 1-800-548-9123