## EXTENSION KIT FOR

## EAST JORDAN BR MIDWEST FIRE HYDRANTS

## SPECIFICATIONS


		A service of the serv	55 A 189 J
ITEM NUMBER	DESCRIPTION	MATERIAL	QTY.
1	Standpipe Gasket	Cloth-Inserted SBR Rubber	2
2	Extension Barrel	Ductile	1
3	Extension Stem	Steel	1
4	Bolt & Nut	Zinc-Plated Steel	8
5	Extension Stem Coupling	Steel	ī
6	Cotter Pin	Stainless Steel	2
7	Clevis Pin	Stainless Steel	2

SIZE: 51/4" Main Valve Opening

HRPI Products are engineered and manufactured using the latest computerized technology to ensure quality products with repeatable tolerances.

HRPI Guarantees this product to be compatible, and will operate with the fire hydrant when installed properly. The use of this product shall not affect any published warranties available to the buyer.

PRODUCTS MEET OR EXCEED THE AWWA C502 STANDARD FOR DRY-BARREL FIRE HYDRANTS.



FAX: (918) 224-6857

## Hydrant Repair Parts, Inc.

7900 New Sapulpa Road, Tulsa, OK 74131 • (918) 224-8713

1-800-776-8713 or 1-800-548-9123

East Jordan is a registered trademark of East Jordan iron Works, Inc., East Jordan, Michigan, Hydrant Repair Parts, Inc., is not stillined with East Jordan iron Works, Inc.